

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 357

Dated: 12/06/2024

It is certified that an inspection team headed by Assistant Engineer

(Name of Officers with designation) from PHE Deptt.

(Name of Department/ Office) inspected the Vidya Path Shali vidyalaya, Delhi

(Name & Address of the school) on 11/06/24 (date of inspection) and found that the Vidya Path Shali Vidyalaya, Rehli (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 03

Signature with Seal:

Asstt. Engineer
P. H. E. Sub Div. 1
Sagar (M.P.)

Name

SHWETANK CHAUHAN

Designation

ASSISTANT ENGINEER


Name & Address of the Office / Department: PHE Sub Div

To


Vidya Path Shali vidyalaya,
Jabalpur Bypass, Rehli, Sagar (M.P.).

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Manager
Vidya Path Shali V. Iyalya
Rehli, Distt.-Sagar (M.P.)



PRINCIPAL
Vidya Path Shali Vidyalaya
Rehli, Sagar (M.P.)

District Water testing Laboratory, (D.W.T.L.)
Public Health Engineering Department, P.H.E.D.
Near TahseelSagar
Test Report

Nature of sample :- Drinking Water Sample / Others		Not sampled by District Water testing Lab		Unique Identification No.	
Sender's name and address: VIDHYA PATH STHALI VIDYALAYA JABALPUR BYPASS, SAGAR ROAD, REHLI, SAGAR M.P.		Sender's letter no. DWTL Ref. No		Sender's letter Date DWTL receipt date	
		36/24		10/06/2024	
Date of analysis started		11/06/2024		Date of analysis completed	
Quantity Of sample		sufficient		12/06/2024	

Sample details

Particulars of Samples :-			
No.	Block	Panchayat	Village
1	REHLI	REHLI	REHLI
2			
3			
4			
5			

RESULTS

No.	Characteristics ,unit and test methods	BIS -10500:2012		Test Results				
		Desirable Limit	Permissible Limit	1	2	3	4	5
1	Chloride as Cl in mg/l, (IS 3025 Part 32)	250	1000	20	-	-	-	-
2*	Total Alkalinity as CaCO ₃ in mg/l, (IS 3025 Part 23)	200	600	160	-	-	-	-
3*	Calcium as Ca++ in mg/l, (IS 3025 Part 40)	75	200	44	-	-	-	-
4*	Magnesium as Mg++ in mg/l, (IS 3025 Part 46)	30	100	26	-	-	-	-
5*	Total hardness as CaCO ₃ in mg/l, (IS 3025 Part 21)	200	600	220	-	-	-	-
6	pH (pH scale)	6.5 to 8.5	6.5 to 8.5	7.2	-	-	-	-
7	Iron as Fe Mg/l	1.0	1.0	0.12	-	-	-	-
8	Nitrate as NO ₃ Mg/l	45	45	5.2	-	-	-	-
9	Fluoride as F Mg/l	1.0	1.5	0.18	-	-	-	-
10	TDS Mg/l	500	2000	400.2	-	-	-	-
11	Turbidity NTU	1.0	5.0	2.1	-	-	-	-
12	Sulphate as SO ₄ Mg/l	200	400	16.00	-	-	-	-
13	Manganese as MnMg/l	0.1	0.3	0.0	-	-	-	-
14	Faecal Coliform (TTC) per 100 ml	NIL		0.0	-	-	-	-
15	Total Coliform per 100 ml	NIL for treated water and water in distribution system		-	-	-	-	-
16	Arsenic By Kit Mg/l	0.01	0.01	0.0	-	-	-	-

- This report should not be produced partly or full without approval of signatory authority for legal purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
- The results refer only to tested samples and parameters tested
- Samples will be stored for a period of 7 days from the date of issue of report. (For tests from S.No. 1 to 17)
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
- The tests marked with an * are accredited by NABL.

Remark:-

Archit
CHEMIST
TECHNICAL MANAGER
DISTRICT WATER
TESTING LABORATORY
P.H.E.DEPPT., SAGAR

Shwetank Chourisia
QUALITY MANAGER
DISTRICT WATER
TESTING LABORATORY
P.H.E.DEPPT., SAGAR

Issue No 36 /D.W.T.L./PHED/SAG /2023-24 Issue Date- 12/06/2024

Manager
VIDHYA PATH STHALI VIDYALAYA
SAGAR (M.P.)

Principal
VIDHYA PATH STHALI VIDYALAYA
REHLI, SAGAR (M.P.)