

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 27Dated: 03/02/2026

It is certified that an inspection team headed by Assistant Engineer
(Name of Officers with designation) from PHE Deptt.

PHED inspected the Vidhya Path Sthali Vidhyalaya, Jabalpur By-pass, Sagar Road, Rehli, Dist. - Sagar, MP
on 02/02/2026 and on the basis of Water Test Report (Attached) bearing no. 27
dated 03/02/2026 of DWTL PHED SAGAR

(PHED Lab) certified that the Vidhya Path Sthali Vidhyalaya, Jabalpur By-pass, Sagar Road, Rehli, Dist. - Sagar, MP has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with seal

Neha
सहायक यंत्री
लोक स्वा. यॉ. उपखण्ड
क्र.1 सागर (म.प्र.)

Name

:- NEHA VERMA

Designation

:- ASSISTANT ENGINEER

Name & address of the office/Department: -

PHE sub Dn Sagar

To,
Vidhya Path Sthali Vidhyalaya,
Jabalpur By-pass, Sagar Road, Rehli, Dist. - Sagar, MP
(Name and address of the institution)

R/w

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies
PRINCIPAL
Vidhya Path Sthali Vidyalaya
Rehli, Sagar (M.P.)

District Water testing Laboratory, (D.W.T.L.)
Public Health Engineering Department.P.H.E.D.
Near TahseelSagar
Test Report

Issue No 27 D.W.T.L./PHED/SAG /2026-27

Issue Date 03/02/2026

Nature of sample :- Drinking Water Sample / Others	Not sampled by District Water testing Lab		Unique Identification No.	
Sender's name and ADDRESS VIDHYA PATH STHALI VIDYALAYA JABALPUR BYPASS SAGAR ROAD REHLI SAGAR	Sender's letter no.	-	Sender's letter Date	
	DWTLRef. No	27/26	DWTL receipt date	
	Date of analysis started	02/02/2026	Date of analysis completed	
	Quantity Of sample			

Sample details

Particulars of Samples :-			Village	Location
No.	Block	Panchayat	REHLI	NEAR SCHOOL
1	REHLI	REHLI		
2				
3				
4				
5				
6				

RESULTS

No.	Characteristics ,unit and test methods	BIS -10500:2012		Test Results				
		Desirable Limit	Permissible Limit	1	2	3	4	5
	2	3	4					
1*	Chloride as Cl in mg/l, (IS 3025 Part 32)	250	1000	46				
2*	Total Alkalinity as CaCO ₃ in mg/l, (IS 3025 Part 23)	200	600	94				
3*	Calcium as Ca ⁺⁺ , in mg/l, (IS 3025 Part 40)	75	200	46				
4*	Magnesium as Mg ⁺⁺ , in mg/l, (IS 3025 Part 46)	30	100	11.1				
5*	Total hardness as CaCO ₃ in mg/l, (IS 3025 Part 21)	200	600	214				
6	pH (pH scale)	6.5 to 8.5	6.5 to 8.5	7.1				
7	Iron as Fe Mg/l	1.0	1.0	0.10				
8	Nitrate as NO ₃ Mg/l	45	45	2.8				
9	Fluoride as F Mg/l	1.0	1.5	0.12				
10	TDS Mg/l	500	2000	332.4				
11	Turbidity NTU	1.0	5.0	0.0				
12	Sulphate as SO ₄ Mg/l	200	400	3.6				
13	Manganese as MnMg/l	0.1	0.3	0.0				
14	Faecal Coliform (TTC) per 100 ml	NIL		-				
15	Total Coliform per 100 ml	NIL for treated water and water in distribution system		0.0				
16	Arsenic By Kit Mg/l	0.01	0.01	-				

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 7 days from the date of issue of report. (For tests from S.No. 1 to 17)
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. The tests marked with an * are accredited by NABL.

Remark:-

Reviewed

Shame

R.j.w
PRINCIPAL
Vidhya Path Sthali Vidyalaya
Rehli, Sagar (M.P.)

Authorised Signatory

Shame
सहायक यंत्री
लोक स्वा. यो. उपखण्ड
क्र.1 सागर (म.प्र.)